

महाराष्ट्र शासन



प्राथमिक आरोग्य केंद्र सोनावळा



ई मेल- sonavalephc@gmail.com

प्रा.आ.के.सो./ आस्था/ वशी/ ४८ /२०२४
दिनांक:- १६/०२/२०२४

SAFE SANITARY CONDITION

CERTIFICATE.



No. _____

Date: 16/02/2024

It is certified that an inspection team headed by **Dr. Archana Garud (M.O)**
(Name of Officers with designation) From P.H.C. SONAVALE
(Name of Department/Office inspected the **Holy Writ High School & Junior College**
Pimploli (Name & Address of the School) on **16/02/2024** and found that the **Holy Writ**
High School & Junior College (Name of school) has safe drinking water facilities for the
students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per the norms prescribed
by the Central/State/U.T Govt.

The above valid for a period of 1 year i.e (2024-2025)

Signature with Seal : Archana Garud
16/2/24

Medical Officer

Name: Primary Health Centre Sonavale
Dist. Thane

Designation

To

Holy Writ High School & Junior College
Pimploli Village, Near Barvi Dam, Badlapur
Thane.

(Name & Address of the Institution)

TEST REPORT

NAME & ADDRESS OF CUSTOMER:

HOLY WRIT HIGH SCHOOL & JUNIOR COLLEGE
PIMPOLI VILLAGE, NEAR BARVI DAM, BADLAPUR (WEST)
MH 421503.

REPORT NO : SAL/MSP19/FM03/02/DW(23-24-1343)

REPORT DATE : 29/02/2024

CUSTOMER REF : Verbal

REF DATE : 27/02/2024

SAMPLE TYPE: Drinking Water

SAMPLE REGISTRATION NO. : 02/DW(23-24-1343)

LOCATION : Tap Water

SAMPLING PLAN & METHOD NO: IS 3025 Part 1

SAMPLE SPECIFICATION : Drinking Water

SAMPLING DATE : 27/02/2024

SAMPLING TIME : 13:25:00

SAMPLE COLLECTED BY : Party

ANALYSIS START DATE : 27/02/2024

SAMPLE QUANTITY : 2 Ltr

ANALYSIS COMPLETE DATE : 29/02/2024

SAMPLE PACKING : sealed

Sr.No.	Test Parameters	Unit	Result	Norms#	Reference Method
1	E-Coli	/100 ML	ABSENT	ABSENT	IS 15185
2	Silica	mg/L	<0.2	NS	IS 3025 (Part 35)
3	Alkalinity to Methyl orange	mg/L	10	200	IS 3025 (Part-23)
4	Phenolphthalein Alkalinity	mg/L	<5	200	IS 3025 (Part 23)

ND: Not Detected. NS: Not Specified.#: As per IS 10500:2012.

Opinion/Observation: Analyzed parameters in above tested sample are within limit as per specified standard.

Note : NA

Analyzed By



Atul Shahane

Sr Analyst

For SKYLAB ANALYTICAL LABORATORY




Dr.Datta Mandhare

(Authorized Signatory)

END OF REPORT

1. This report reflects finding only for the above sample tested/monitored and only for time and place of monitoring/testing.
2. This report is confidential & cannot be re-produced in part or full without permission of SKYLAB Analytical Laboratory.
3. Any attempt of forgery or misleading use of this report by any person/organization etc will attract suitable leagal action against them by SKYLAB Analytical Laboratory.



ULR:TC515024000013209F

TEST REPORT

NAME & ADDRESS OF CUSTOMER:	REPORT NO :	SAL/MSP19/FM03/02/DW(23-24-1343)
HOLY WRIT HIGH SCHOOL & JUNIOR COLLEGE	REPORT DATE :	29/02/2024
PIMPOLI VILLAGE , NEAR BARVI DAM, BADLAPUR (WEST)	CUSTOMER REF :	Verbal
MH 421503.	REF DATE :	27/02/2024

SAMPLE TYPE: Drinking Water

SAMPLE REGISTRATION NO. :	02/DW(23-24-1343)	LOCATION :	Tap Water
SAMPLING PLAN & METHOD NO.:	IS 3025 Part 1	SAMPLE SPECIFICATION :	Drinking Water
SAMPLING DATE :	27/02/2024	SAMPLE COLLECTED BY :	Party
SAMPLING TIME :	13:25:00	SAMPLE QUANTITY :	2 Ltr
ANALYSIS START DATE :	27/02/2024	SAMPLE PACKING :	sealed
ANALYSIS COMPLETE DATE :	29/02/2024		

Sr.No.	Test Parameters	Unit	Result	Norms#	Reference Method
1	pH	Units	7.64	6.5-8.5	IS 3025 (Part 11)
2	Turbidity	NTU	<1	1	IS 3025 (Part 10)
3	Total Dissolved Solids	mg/L	46	500	IS 3025 (Part 16)
4	Calcium, as Ca	mg/L	<5	75	IS 3025 (Part 40)
5	Iron, as Fe	mg/L	<0.1	0.3	IS 3025 (Part 2)
6	Magnesium, as Mg	mg/L	2	30	IS 3025 (Part 46): 1994
7	Nitrate, as NO3	mg/L	<0.1	45	IS 3025 (Part 34)
8	Sulphate, as SO4	mg/L	<1	200	IS 3025 (Part 24)
9	Chloride, as Cl	mg/L	15	250	IS 3025 (Part 32)
10	Total Alkalinity, as CaCO3	mg/L	10	200	IS 3025 (Part 23): 1986
11	Total hardness, as CaCO3	mg/L	16	200	IS 3025 (Part 21): 2009

ND: Not Detected. NS: Not Specified.#: As per IS 10500:2012.

Opinion/Observation: Analyzed parameters in above tested sample are within limit as per specified standard.

Note : NA

Analyzed By



Atul Shahane
Sr Analyst

For SKYLAB ANALYTICAL LABORATORY




Dr.Datta Mandhare
(Authorized Signatory)

END OF REPORT

SALAC24230911477